

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 11:36 am

**PWS ID:** UTAH02043      **Name:** PARK VALLEY SCHOOL  
**Legal Contact:** PARK VALLEY SCHOOL      **Rating:** Approved  
BRIAN ANDERSON      **Rating Date:** 11/14/2007  
**Address:** 788 EDUCATION DR      **Activity Status:** Active  
PARK VALLEY, UT 84329  
**Phone Number:** 435-734-4800  
**City Served (Area):**  
**County:** BOX ELDER COUNTY  
**System Type:** Non Transient      **Last Inv Update:** 07/28/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 11/17/2009      **Total Dsgn Cap:**  
**Population:** 50      **Surveyor:** RICHARD WORLEY      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day    Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers Office	Emergency	Email Address
AC	ANDERSON, BRIAN		435-871-4411		brian.anderson@besd.net

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	2
			2 Total Svc Connections

### Storage

**Total Storage:** 300 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matl	Overflow Elev	Activity Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	150 GAL	Steel		A	
ST002	STORAGE FACILITY ST002	Ground	150 GAL	Steel		A	

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	NO. SCHOOL WELL	Active	WL	8	10 GPM	5 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS002	2002 WELL	Active	WL			8 GPM	Yes	GW	Permanent	1/1 to 12/31	

\*Reports measured flow for wells, approved design capacity for all other sources.